

WARNINGS



RISK OF FIRE, ELECTRICAL SHOCK, CUTS OR OTHER CASUALTY HAZARDS

Installation and maintenance of this product must be performed by a qualified electrician. This product must be installed in accordance with the applicable installation code by a person familiar with the construction and operation of the product and hazards involved.

RISK OF FIRE AND ELECTRIC SHOCK

Make certain power is OFF before starting installation or attempting any maintenance. Disconnect power at fuse or circuit breaker.

RISK OF FIRE

Refer to product label for specific minimum supply conductor requirements.

RISK OF BURN

Disconnect power and allow fixture to cool before handling or servicing.

RISK OF PERSONAL INJURY

Fixture may become damaged and/or unstable if not installed properly.

DISCLAIMER OF LIABILITY: CSC LED assumes no liability for damages or losses of any kind that may arise from the improper, careless, or negligent installation, handling or use of this product.


NOTICE: Green ground wire is provided in proper location. Do not relocate.

SAFETY: This fixture must be wired in accordance with the National Electrical Code and applicable local codes and ordinances. Proper grounding is required to ensure personal safety. Carefully observe grounding procedure under installation section.

APPLICATIONS: This lighting fixture is designed for indoor lighting applications, and should not be used in an area with limited ventilation or inside high ambient temperature enclosures. It must be stored in a dry location prior to installation.

ATTENTION RECEIVING DEPARTMENT: Note actual fixture description of any shortage or noticeable damage on delivery receipt. File claim for common carrier (LTL) directly with carrier. Claims for concealed damage must be filed within 15 days of delivery. All damaged material, complete with original packaging must be retained.

PLEASE SEE MS02-RC INSTRUCTIONS FOR SENSOR PROGRAMMING WITH THE REMOTE CONTROL



SPECIFICATIONS & NOTES

| | |
|--------------------------|------------------------------|
| Power Supply | 12V DC |
| HF System | 5.8GHz ± 75 MHz |
| Dim Control Output | 0-10V max |
| Detection Radius / Angle | 16 ft max (5m) / 360° |
| Mounting Height | 12 ft max (3.6 m) |
| Remote Range | 25 ft (7.7 m) |
| Humidity | Max 95% RH |
| Temperature | -40°F ~ 158°F (-40°C ~ 70°C) |

NOTE: MAXIMUM MOUNTING HEIGHT IS 12 FT (3.6 M)


1. When the luminaire is switched on, there is a 15 second initialization period where the light will flash on and off, and then dim. It will remain dimmed for the current Stand-By Time, or until motion is detected.

2. When settings are changed, the luminaire will flash on and then turn off. It will remain off until motion is detected.


FACTORY DEFAULT SETTINGS:

| SENSITIVITY | HOLD TIME | DAYLIGHT SENSOR | STAND-BY DIM | STAND-BY TIME |
|-------------|-----------|-----------------|--------------|---------------|
| 100% | 5 minutes | Disabled | 0% | 1 minute |


WIRING DIAGRAMS




Yellow: 12V+
 Pink: Dim -
 Violet: Dim +



SENSOR MOUNTING



SENSOR COVERAGE



NOTES:

Be cautious if installing this sensor in areas with a large presence of metal (such as walls or machinery). Microwaves can reflect off metal surfaces and can potentially lead to false detection of movement.

In order to test the Sensitivity level, keep the Hold Time and Stand-By Time low so that the full cycle can quickly be observed. Once the sensitivity is confirmed through testing, the Hold Time and Stand-By time can be set to the desired levels.

It is recommended to start on a lower Sensitivity setting and increase as needed. Microwaves can pass through most non-metal materials (including drywall and wood) and could detect motion on the other side of walls.

For indoor applications the Daylight Sensor is typically not used and should be disabled.

Please see MS02-RC instructions for sensor programming with the remote control